

Classification Report

Number	17-003792-PR02 (NW-A01-02-en-01)
Owner	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Product	Louvred window
Designation	System: SH3300 Shipping name: SH3300 - Glass louvre system
Details	Manufacturer ALUMINCO S.A., - Inofita Viotias; Material Aluminium; Type of opening Louvred window with intermediate axis; Opening direction Outwards; Overall dimensions (W x H) 800 mm x 1000 mm
Special features	-/-

Result

Watertightness according to EN 12208:1999-11



Class: 2A

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
e.g. DIN EN)

Test report: 17-003792-PR02 PB-A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

23.02.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Thomas Krichbaumer
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 85B-85AD7