


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 1077 / 19.07.2010**

NUMBER	1077	DATE	19 / 07 / 2010
---------------	-------------	-------------	-----------------------

Client' s data:	EUROPA PROFIL ALUMINIUM S.A. ALUMINIUM EXTRUSION INDUSTRY 56th klm. NATIONAL ROAD ATHINON -LAMIAS GR 320 11 INOFITA VIOTIAS GREECE
Product description:	SINGLE SASH ENTRANCE DOOR OPENING
Material:	ALUMINIUM
System :	EUROPA 500



1000 x 2200mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 3
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 5B / 4A
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C3

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPADOPOULOU
LABORATORY MANAGER**



**IOANNIS GKERTSOS
GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL