

# Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



## Test Report

No. 15-001044-PR18

(PB-A01-02-en-02)

**Client** Europa Profil Aluminium S.A.  
56th Klm National Highway, Athens - Lamia  
32011 Innofita Viotas  
Greece

**Product** Double sash tilt and turn window

**Designation** System: Prima 8500 Multi double sash

**Performance-relevant product details** Aluminium profiles with thermal break

**Overall dimensions (WxH)** 1600 mm x 2200 mm

**Special features** The test sequence was changed by clients requirements

## Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12046-1:2003-11

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Test report 15-001044-PR18 (PB-A01-02-en-01) dated 26.01.2016

## Representation



## Results

Air permeability according to EN 12207:1999-11



**Class 4**

Watertightness according to EN 12208:1999-11



**Class 7A**

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



**Class C3 / B4**

## Instructions for use

The results obtained can be used by the manufacturer for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The provisions of the applicable product standard have to be observed.

## Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

## Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 28 pages.

ift Rosenheim

10.02.2016

Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Construction Product Testing

Herbert Niedermeier  
Testing Staff  
Construction Product Testing